

# DECLARATION of Conformity

Order No.: MTE/MYX/8030184

Holder: **Shenzhen P&H Electronic Co., Ltd.**  
**F1.5, Manjinghua Ind. Bldg., Kaifeng Rd. Shang Meilin,**  
**Futian Zone, Shenzhen, P.R. China**

Equipment Description: FIRE ALARM

Model Name: EM203, EM202, EM204, EM205, EM206, EM207, EM208,  
EM209

Technical Data: DC 24V

The submitted products have been tested by us with the listed standards and found in compliance with the following European Directives:

**The EMC directive 2004/108/EC**

EN55022:2006  
EN50130-4:1995+A1:1998+A2:2003

The tests were performed in normal operation mode. The test results apply only to the particular sample tested and to the specific tests carried out.

This certificate applies specifically to the sample investigated in our test reference number only.

The CE markings as shown below can be affixed on the product after preparation of necessary technical documentation.

Other relevant Directives have to be observed.

March 17, 2008



Mark Wen  
For Chief Executives



**Most Compliance Laboratory Limited**  
No. 5, 2nd Langshan Road, North District, Hi-tech Industrial Park,  
Nanshan, Shenzhen, Guangdong, China  
Tel: 86 755 8617 0306 Fax: 86 755 8617 0310